

ADDENDUM #6 – September 29, 2022

CLARIFICATION ON PROJECT PILING SPECIFICATIONS

City of Warrenton Marina Commercial Work Pier Rehab Improvements Project

CLARIFICATION ON PROJECT PILING SPECIFICATIONS

Q: What are the pile lengths?

A: Fender pile lengths are estimated at 65 feet each, but actual length to be determined by site conditions.

Q: Is Canadian Steel allowed?

A: Regarding the Canadian steel. As long as the steel materials meet the project specifications, the origin of the steel does not matter.