ADDENDUM NO. 3

TO THE

CONTRACT DOCUMENTS

FOR

RAW WATERLINE REPLACEMENT

FOR

CITY OF WARRENTON

THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS TO THE SAME EXTENT AS THOUGH IT WERE ORIGINALLY INCLUDED THEREIN.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON THE BID PROPOSAL FORM. BID PROPOSALS THAT FAIL TO ACKNOWLEDGE ALL ADDENDA MAY BE CONSIDERED IRREGULAR AND MAY BE REJECTED.

ISSUED THIS 19TH DAY OF MAY 2022.



MURRAYSMITH 400 E Mill Plain Blvd, Suite 400 Vancouver, WA 98660 (360) 448-4230

ITEM NO. 1 - SPECIAL PROVISIONS, SECTION 00120.01 RECEIPT OF BIDS; OPENING.

Delete the sentence "Bids will be publicly opened and read by the Public Works Director, or authorized designee, at **2:00 PM**, local time on **May 24, 2022**, at the Commission Chambers in Warrenton City Hall" and replace with the following sentence:

"Bids will be publicly opened and read by the Public Works Director, or authorized designee, at **2:00 PM**, local time on **Thursday**, **May 26**, **2022**, at the Commission Chambers in Warrenton City Hall."

ITEM NO. 2 - BID SCHEDULE

Replace the Bid Schedule with the attached Revised Bid Schedule- Addendum No. 3. The quantity for Bid Item 7 has been revised, replacing "2,235 LF" with "2,330 LF."

END ADDENDUM NO. 3

REVISED BID SCHEDULE – ADDENDUM NO. 3 RAW WATERLINE REPLACEMENT

| Bid Item No. | Description | Quantity | Unit | Unit Price | Bid Amount |
|--------------------|--|----------|------|------------|------------|
| 1 | Mobilization | 1 | LS | | |
| 2 | Record Drawings | 1 | LS | | |
| 3 | Construction Survey Work | 1 | LS | | |
| 4 | Temporary Work Zone Traffic Control | 1 | LS | | |
| 5 | Erosion and Sediment Control | 1 | LS | | |
| 6 | Tree Removal | 1 | LS | | |
| 7 | 24-in HDPE (IPS) DR17 Waterline | 2,330 | LF | | |
| 8 | 18-in DI CL52 Waterline | 20 | LF | | |
| 9 | 16-in DI CL52 Waterline | 20 | LF | | |
| 10 | 24-in Butterfly Valve | 1 | EA | | |
| 11 | 18-in Butterfly Valve | 1 | EA | | |
| 12 | 16-in Butterfly Valve | 1 | EA | | |
| 13 | 2-in Combination Air Release/Vacuum Valve Assembly | 2 | EA | | |
| 14 | Fire Hydrant Assembly | 1 | EA | | |
| 15 | Trench Protection and Dewatering | 1 | LS | | |
| 16 | Connection to Existing Waterline | 4 | EA | | |
| 17 | Abandon Existing Waterline | 1 | LS | | |
| 18 | Stone Surfacing Pad | 850 | SF | | |

Total Bid Amount